

# Specific energy for heating (monthly method)

Energy balance calculation with PHPP Version 9.6a

Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)

The sum of the heating periods calculated through the monthly method will be presented on this side.

Interior temperature:	18	°C
Building type:	Kultūras nams	
Treated floor area A <sub>TFA</sub> :	1050,2	m²
Spec. Capacity:	204	Wh/(m²K)

Building assembly	Temperature zone	Area m²	U-Value W/(m²K)	Month. red. fac.	G <sub>i</sub> kKh/a	kWh/a	Per m² of treated floor area
External wall - Ambient	A	790,12	1,242	1,00	105,08	103112	98,18
External wall - Ground	B			1,00			
Roof/Ceiling - Ambient	A	688,64	0,986	1,00	105,08	71378	67,97
Floor slab / Basement ceiling	B	692,29	1,442	1,00	27,94	27889	26,56
	A			1,00			
	A			1,00			
	X			0,75			
Windows	A	168,72	1,305	1,00	105,08	23130	22,02
Exterior door	A	5,76	2,000	1,00	105,08	1209	1,15
Exterior TB (length/m)	A	636,60	0,061	1,00	105,08	4059	3,86
Perimeter TB (length/m)	P	160,98	0,090	1,00	27,94	405	0,39
Ground TB (length/m)	B			1,00			0,00
						Total	220,1

Transmission heat losses Q<sub>T</sub>

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Ventilation losses ambient Q<sub>V</sub>

Ventilation losses ground Q<sub>V,e</sub>

Ventilation heat losses Q<sub>V</sub>

		Q <sub>T</sub> kWh/a	Q <sub>V</sub> kWh/a	Reduction factor night/weekend saving	kWh/a	kWh/(m²a)
		231181	58027	1,0	289209	275,4

Total heat losses Q<sub>L</sub>

Orientation of the area	Reduction factor see 'Windows' worksheet	g-Value (perp. radiation)	Area m²	Global radiation kWh/(m²a)	kWh/a	kWh/(m²a)
North	0,49	0,64	40,6	284,20	3618	
East	0,40	0,64	51,8	604,07	7963	
South	0,43	0,64	47,8	660,79	8592	
West	0,35	0,64	28,6	479,75	3059	
Horizontal	0,00000	0,00	0,0	985,38	0	
Sum opaque areas					46271	
					Total	66,2

Available solar heat gains Q<sub>S</sub>

		Length Heat. Period kh/d	Spec. Power q <sub>i</sub> W/m²	A <sub>TFA</sub> m²	kWh/a	kWh/(m²a)
		0,024	365	1,8	1050,2	16468
					kWh/a	kWh/(m²a)
					85970	81,9
					Q <sub>S</sub> + Q <sub>i</sub>	
					Q <sub>F</sub> / Q <sub>L</sub>	0,30
						77,08%
					η <sub>G</sub> * Q <sub>F</sub>	63,1

Heat gains Q<sub>G</sub>

		Q <sub>L</sub> - Q <sub>G</sub>	kWh/a	kWh/(m²a)
			222943	212
		Limiting value	-	
		Requirement met?	-	

Annual heating demand Q<sub>H</sub>

Limiting value

# Specific energy for heating (monthly method)

Energy balance calculation with PHPP Version 9.6a


Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)

Interior temperature: 18 °C

Building type: Kultūras nams

Treated floor area A<sub>TFA</sub>: 1050 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating degree hours - Exterior	16,0	14,7	13,7	9,0	5,4	2,7	0,9	1,6	5,0	9,1	12,1	15,0	105	kKh
Heating degree hours - Ground	3,4	3,2	3,4	2,9	2,4	1,7	1,3	1,2	1,3	1,8	2,3	3,0	28	kKh
Losses - Exterior	39737	36403	34118	22315	13446	6700	2126	3906	12322	22573	29930	37338	260915	kWh
Losses - Ground	3466	3289	3487	2946	2432	1755	1355	1179	1290	1776	2312	3007	28294	kWh
Sum spec. losses	41,1	37,8	35,8	24,1	15,1	8,1	3,3	4,8	13,0	23,2	30,7	38,4	275,4	kWh/m²
Solar gains - North	52	106	243	377	556	635	612	471	302	166	64	34	3618	kWh
Solar gains - East	148	264	556	880	1188	1185	1186	1035	748	478	179	115	7963	kWh
Solar gains - South	218	367	691	975	1116	1027	1106	1076	895	669	273	180	8592	kWh
Solar gains - West	33	75	190	336	499	525	530	412	251	134	48	25	3059	kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar gains - Opaque	583	1208	2972	5164	7378	7596	7688	6268	4021	2211	765	417	46271	kWh
Internal heat gains	1399	1263	1399	1353	1399	1353	1399	1399	1353	1399	1353	1399	16468	kWh
Sum spec. gains solar + internal	2,3	3,1	5,8	8,7	11,6	11,7	11,9	10,2	7,2	4,8	2,6	2,1	81,9	kWh/m²
Utilisation factor	100%	100%	100%	100%	94%	66%	28%	47%	98%	100%	100%	100%	77%	
Annual heating demand	40771	36409	31556	16191	4466	327	2	37	6157	19292	29559	38176	222943	kWh
Spec. heating demand	38,8	34,7	30,0	15,4	4,3	0,3	0,0	0,0	5,9	18,4	28,1	36,4	212,3	kWh/m²



## Annual heating demand: Comparison


Monthly method	( <i>Heating</i> )	222943 kWh/a	212,3 kWh/(m²a) reference to treated floor area according to PHPP
Annual method	( <i>Annual heating</i> )	218816 kWh/a	208,4 kWh/(m²a) reference to treated floor area according to PHPP
		- kWh/a	-

Ēkas platības										
Stāvs	Numurs	Nosaukums	Kopējā			TFA koef.	Apkurināmā		Tin, °C	Tin avg, °C
			Platība, m²	Augstums, m	Tilpums, m³		TFA, m²	TFV, m³		
1	1	Gērbtuve	26,00	2,20	57,20	1	26,00	57,20	18,00	0,28
	2	Elektrosadales telpa	3,30	3,00	9,90	1	3,30	9,90	18,00	0,05
	3	Kāpņu telpa	13,80	3,00	41,40	1	13,80	41,40	18,00	0,20
	4	Vējtveris	7,20	3,00	21,60	1	7,20	21,60	18,00	0,10
	5	Veikals	25,20	3,00	75,60	1	25,20	75,60	18,00	0,37
	6	Gērbtuve	25,90	3,00	77,70	1	25,90	77,70	18,00	0,38
	7	Kabinets	12,70	3,00	38,10	1	12,70	38,10	18,00	0,18
	8	Gaitenis	3,50	3,00	10,50	1	3,50	10,50	18,00	0,05
	9	Palīgtelpa	8,30	3,00	24,90	1	8,30	24,90	18,00	0,12
	10	Zāle	246,00	5,80	1426,80	1	246,00	1426,80	18,00	6,90
	11	Gaitenis	117,70	3,00	353,10	1	117,70	353,10	18,00	1,71
	12	Vējtveris	19,20	2,65	50,88	1	19,20	50,88	18,00	0,25
	13	Tualete	7,80	3,00	23,40	1	7,80	23,40	18,00	0,11
	14	Tualete	6,00	3,00	18,00	1	6,00	18,00	18,00	0,09
	15	Bibliotēka	15,10	3,00	45,30	1	15,10	45,30	18,00	0,22
	16	Bibliotēka	22,80	3,00	68,40	1	22,80	68,40	18,00	0,33
	17	Gaitenis	16,90	3,00	50,70	1	16,90	50,70	18,00	0,25
	18	Medicīnas kabinets	9,00	3,00	27,00	1	9,00	27,00	18,00	0,13
	19	Priekštelpa	13,60	3,00	40,80	1	13,60	40,80	18,00	0,20
	20	Tualete	2,00	3,00	6,00	1	2,00	6,00	18,00	0,03
	21	Medicīnas kabinets	16,80	3,00	50,40	1	16,80	50,40	18,00	0,24
	22	Kabinets	17,30	3,00	51,90	1	17,30	51,90	18,00	0,25
	23	Katlu telpa	14,00	2,40	33,60	1	14,00	33,60	18,00	0,16
2	24	Kabinets	26,60	2,80	74,48	1	26,60	74,48	18,00	0,36
	25	Palīgtelpa	6,00	2,80	16,80	1	6,00	16,80	18,00	0,08
	26	Kāpņu telpa	13,80	2,80	38,64	1	13,80	38,64	18,00	0,19
	27	Kabinets	10,80	2,80	30,24	1	10,80	30,24	18,00	0,15
	28	Kabinets	30,80	2,80	86,24	1	30,80	86,24	18,00	0,42
	29	Kabinets	15,20	2,80	42,56	1	15,20	42,56	18,00	0,21
	30	Kabinets	26,50	2,80	74,20	1	26,50	74,20	18,00	0,36
	31	Noliktava	5,60	2,80	15,68	1	5,60	15,68	18,00	0,08
	32	Noliktava	15,50	2,80	43,40	1	15,50	43,40	18,00	0,21
	33	Elektrosadales telpa	10,40	2,80	29,12	1	10,40	29,12	18,00	0,14
	34	Tualete	7,50	2,80	21,00	1	7,50	21,00	18,00	0,10
	35	Tualete	6,10	2,80	17,08	1	6,10	17,08	18,00	0,08
	36	Kabinets	7,30	2,80	20,44	1	7,30	20,44	18,00	0,10
	37	Kabinets	14,70	2,80	41,16	1	14,70	41,16	18,00	0,20
	38	Kabinets	14,60	2,80	40,88	1	14,60	40,88	18,00	0,20
	39	Gaitenis	17,40	2,80	48,72	1	17,40	48,72	18,00	0,24
	40	Kabinets	16,60	2,80	46,48	1	16,60	46,48	18,00	0,22
	41	Kabinets	17,10	2,80	47,88	1	17,10	47,88	18,00	0,23
	42	Kabinets	17,00	2,80	47,60	1	17,00	47,60	18,00	0,23
	43	Kabinets	8,80	2,80	24,64	1	8,80	24,64	18,00	0,12
	43	Gaitenis	111,80	2,80	313,04	1	111,80	313,04	18,00	1,51
-1	44	Pagrabs	26,00	2,20	57,20	0	0,00	0,00	0,00	0,00
		<b>KOPĀ</b>	<b>1076,20</b>	<b>3,55</b>	<b>3780,66</b>		<b>1050,20</b>	<b>3723,46</b>		<b>18,00</b>

## Climate data

Energy balance calculation with PHPP Version 9.6a

Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)



# U-value of building assemblies

Energy balance calculation with PHPP Version 9.6a

Kultūras nams / Climate: Jelgava / TFA: 1050 m<sup>2</sup> / Heating: 212,3 kWh/(m<sup>2</sup>a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m<sup>2</sup>a)

Secondary calculation: Equivalent thermal conductivity of still air spaces -> (on the right)

Wedge-shaped assembly layer -> (on the right)

Unheated / uncooled attic -> (on the right)

Assembly no.	Building assembly description					Interior insulation?
01ud	Grīda uz grunts/ zāle					
Heat transmission resistance [m <sup>2</sup> K/W]						
Orientation of building element	3-Floor	interior R <sub>si</sub>		0,17		
Adjacent to	2-Ground	exterior R <sub>se</sub>		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Dēļu klājs	0,130					25
Asfalts	0,700					30
Betons	2,000					183
Šķembas	2,000					70
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						30,8 cm
U-value supplement		W/(m <sup>2</sup> K)		U-value:		1,881 W/(m <sup>2</sup> K)

Assembly no.	Building assembly description					Interior insulation?
02ud	Grīda uz grunts/ pārējās telpas					
Heat transmission resistance [m <sup>2</sup> K/W]						
Orientation of building element	3-Floor	interior R <sub>si</sub>		0,17		
Adjacent to	2-Ground	exterior R <sub>se</sub>		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Grīda uz grunts	0,053					25
Cements	2,000					50
Izdēdži	0,300					40
Betons	2,000					50
Šķembas	2,000					100
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						26,5 cm
U-value supplement		W/(m <sup>2</sup> K)		U-value:		1,147 W/(m <sup>2</sup> K)

Assembly no.	Building assembly description					Interior insulation?
03ud	Ārsienas					
Heat transmission resistance [m <sup>2</sup> K/W]						
Orientation of building element	2-Wall	interior R <sub>si</sub>		0,13		
Adjacent to	1-Outdoor air	exterior R <sub>se</sub>		0,04		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Apmetums	0,900					5
Kieģeļi	0,810					510
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%						51,5 cm
U-value supplement		W/(m <sup>2</sup> K)		U-value:		1,242 W/(m <sup>2</sup> K)

Assembly no.		04ud				<b>Jumts</b>		Interior insulation?	
						Heat transmission resistance [m <sup>2</sup> K/W]			
Orientation of building element		1-Roof		interior R <sub>si</sub>		0,10			
Adjacent to		1-Outdoor air		exterior R <sub>se</sub>		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
Ruberoīds	0,230					7			
Betona lējums	2,000					50			
Keramzīts	0,200					75			
Gāzbetons	0,300					100			
Dz/b panelis	2,000					220			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						45,2 cm			
U-value supplement				U-value:		0,986		W/(m <sup>2</sup> K)	

Assembly no.		05ud				<b>Pagraba siena virs grunts</b>		Interior insulation?	
						Heat transmission resistance [m <sup>2</sup> K/W]			
Orientation of building element		2-Wall		interior R <sub>si</sub>		0,13			
Adjacent to		1-Outdoor air		exterior R <sub>se</sub>		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
Apmetums	0,900					5			
Dz/b	2,000					600			
Apmetums	0,900					5			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						61,0 cm			
U-value supplement				U-value:		2,079		W/(m <sup>2</sup> K)	

Assembly no.		06ud				<b>Pagraba siena zem grunts</b>		Interior insulation?	
						Heat transmission resistance [m <sup>2</sup> K/W]			
Orientation of building element		2-Wall		interior R <sub>si</sub>		0,13			
Adjacent to		2-Ground		exterior R <sub>se</sub>		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
Apmetums	0,900					5			
Dz/b	2,000					600			
Apmetums	0,900					5			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						61,0 cm			
U-value supplement				U-value:		2,267		W/(m <sup>2</sup> K)	

Assembly no.		Interior insulation?			
07ud		Grīda uz grunts			
		Heat transmission resistance [m²K/W]			
Orientation of building element		3-Floor		interior R <sub>si</sub> 0,17	
Adjacent to		2-Ground		exterior R <sub>se</sub> 0,00	
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
Dz/b	2,000				
Šķembas	2,000				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
92%		8,0%			
U-value supplement		W/(m²K)		U-value: 4,348 W/(m²K)	

					Thickness [mm]
					70
					50
					Total
					12,0 cm

Assembly no.		Interior insulation?			
08ud		Pagraba pārsegums			
		Heat transmission resistance [m²K/W]			
Orientation of building element		3-Floor		interior R <sub>si</sub> 0,17	
Adjacent to		3-Ventilated		exterior R <sub>se</sub> 0,17	
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
Dz/b panelis	2,000				
Grīdas segums	0,250				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%					
U-value supplement		W/(m²K)		U-value: 1,887 W/(m²K)	

					Thickness [mm]
					220
					20
					Total
					24,0 cm

## Heat losses through the ground 2

Energy balance calculation with PHPP Version 9.6a

Kultūros namų / Climate: Jėgėna / TFA: 1050 m<sup>2</sup> / Heating: 212.3 kWh(m<sup>2</sup>a) / Freq. overheating: 0 % / PER: 1024.4 kWh(m<sup>2</sup>a)

## Building section 2

Ground characteristics		
Thermal conductivity	λ	2.0 W/(mK)
Heat capacity	ρC	2.0 MJ/(m <sup>3</sup> K)
Periodic penetration depth	δ	3.17 m

Building data			U-value floor slab/basement ceiling	$U_f$	1.514	W/(m <sup>2</sup> K)	
Area of ground floor slab / basement c	A	666.3	m <sup>2</sup>	Tbbs floor slab / basement ceiling	$\Psi_{fb}$	0.00	W/K
Perimeter length	P	161.0	m	U-value floor slab / basement ceiling in	$U_f$	1.514	W/(m <sup>2</sup> K)
Charact. dimension of floor slab	B'	8.28	m	Equivalent thickness floor	$d_f$	1.32	m

## Floor slab type (select only one)

x Slab on grade					
Perimeter insulation width/depth	D	0,00	m	Orientation of perimeter insulation	horizontal
Perimeter insulation thickness	d <sub>pi</sub>	0,00	m	(check only one field)	vertical
Conductivity perimeter insulation	λ <sub>pi</sub>	0,036	W/(mK)		

Heated basement or floor slab completely / partially below ground level						
Basement wall height below ground lev. z		m	U-Value wall below ground	$U_{wB}$		W/(m <sup>2</sup> K)

Unheated basement						
Height aboveground wall	h		m	U-Value wall above ground	$U_{WU}$	$W/(m^2K)$
Basement wall height below ground lev. z			m	U-Value wall below ground	$U_{WB}$	$W/(m^2K)$
Air change unheated basement	n		$h^{-1}$	U-Value basement floor slab	$U_{UB}$	$W/(m^2K)$
Air volume basement	V		$m^3$			

Suspended floor above a ventilated crawl space (at max. 0.5 m below ground)						
U-Value crawl space	$U_{\text{Crawl}}$		W/(m <sup>2</sup> K)	Area of ventilation openings	$\Sigma P$	m <sup>2</sup>
Height of crawl space wall	$h$		m	Wind velocity at 10 m height	$v$	m/s
U-Value crawl space wall	$U_{\text{cr}}$		W/(m <sup>2</sup> K)	Wind shield factor	$f_{\text{W}}$	

Additional thermal bridge heat losses at perimeter			Steady-state fraction	$\Psi_{P,ss} \cdot I$	14,488	W/K
Phase shift	$\beta$	Months	Harmonic fraction	$\Psi_{P,harm} \cdot I$	0,000	W/K

Groundwater correction					
Depth of the groundwater table	$z_g$	3.0	m	Groundwater correction factor	$G_g$ 1.01629058
Groundwater flow rate	$q_g$	0.01	m/d		

Interim results					
Phase shift	$\beta$	0.99 Months	Steady-state heat flow	$\Phi_{ss}$	3147.8 W
Steady-state transmittance	$L_S$	314.78 W/K	Periodic heat flow	$\Phi_{harm}$	631.5 W
Exterior periodic transmittance	$L_{ph}$	145.74 W/K	Heat losses during heating period	$Q_{out}$	20427 kWh
Transmittance building	$L_0$	1023.40 W/K			

## Monthly average temperatures in the ground for monthly method (building assembly 2)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Avg. value
Winter	13.7	13.5	13.6	14.1	14.9	15.6	16.2	16.4	16.2	15.7	15.0	14.2	14.9
Summer	18.5	18.3	18.5	18.0	19.0	19.7	20.5	21.0	21.1	20.6	19.8	19.1	19.8

Design ground temperature for 'Heating load' worksheet

13.5

For 'Cooling load' worksheet

21.2

Reduction factor for 'Annual heating' worksheet

0.93

## Heat losses through the ground 3

Energy balance calculation with PHPP Version 9.6a

Kultūros namų / Climate: Jėgėna / TFA: 1050 m<sup>2</sup> / Heating: 212.3 kWh(m<sup>2</sup>a) / Freq. overheating: 0 % / PER: 1024.4 kWh(m<sup>2</sup>a)

## Building section 3

Ground characteristics		
Thermal conductivity	λ	2.0 W/(mK)
Heat capacity	ρC	2.0 MJ/(m <sup>3</sup> K)
Periodic penetration depth	δ	3.17 m

Building data		U-value floor slab/basement ceiling	$U_f$	1,887	W/(m <sup>2</sup> K)		
Area of ground floor slab / basement c	A	26,0	m <sup>2</sup>	Tbbs floor slab / basement ceiling	$\Psi_{fb}$ '1		
Perimeter length	P	20,5	m	U-value floor slab / basement ceiling in	$U_f$	1,887	W/(m <sup>2</sup> K)
Charact. dimension of floor slab	B'	2,53	m	Equivalent thickness floor	$d_f$	1,06	m

## Floor slab type (select only one)

Slab on grade					
Perimeter insulation width/depth	D	<input type="text"/>	m	Orientation of perimeter insulation	horizontal <input type="text"/>
Perimeter insulation thickness	d <sub>pi</sub>	<input type="text"/>	m	(check only one field)	vertical <input checked="" type="text"/>
Conductivity perimeter insulation	λ <sub>pi</sub>	<input type="text"/>	W/(mK)		

Heated basement or floor slab completely / partially below ground level					
Basement wall height below ground lev. z		m	U-Value wall below ground	$U_{wb}$	$W/(m^2K)$

x Unheated basement						
Height aboveground wall	h	0.20	m	U-Value wall above ground	$U_{wU}$	2.079 W/(m²K)
Basement wall height below ground lev. z		2.00	m	U-Value wall below ground	$U_{wB}$	2.267 W/(m²K)
Air change unheated basement	n	0.20	h <sup>-1</sup>	U-Value basement floor slab	$U_{bB}$	4.348 W/(m²K)
Air volume basement	V	57	m³			

Suspended floor above a ventilated crawl space (at max. 0.5 m below ground)						
U-Value crawl space	$U_{Crawl}$		W/(m <sup>2</sup> K)	Area of ventilation openings	$\Sigma P$	m <sup>2</sup>
Height of crawl space wall	$h$		m	Wind velocity at 10 m height	$v$	m/s
U-Value crawl space wall	$U_{Wl}$		W/(m <sup>2</sup> K)	Wind shield factor	$f_{Wl}$	

Additional thermal bridge heat losses at perimeter			Steady-state fraction	$\Psi_{P,ss}^{\circ}$		W/K
Phase shift	$\beta$	Months	Harmonic fraction	$\Psi_{P,harm}^{\circ}$	0,000	W/K

Groundwater correction					
Depth of the groundwater table	$z_g$	3,0	m	Groundwater correction factor	$G_w$ 1,00025761
Groundwater flow rate	$q_g$	0,01	m/d		

Interim results					
Phase shift	$\beta$	0,63 Months	Steady-state heat flow	$\Phi_{ss}$	282,6 W
Steady-state transmittance	$L_S$	28,26 W/K	Periodic heat flow	$\Phi_{harm}$	113,0 W
Exterior periodic transmittance	$L_{ph}$	23,97 W/K	Heat losses during heating period	$Q_{h,el}$	2138 kWh
Transmittance building	$L_0$	49,01 W/K			

## Monthly average temperatures in the ground for monthly method (building assembly 3)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Avg. value
Winter	7.5	7.2	7.2	8.3	10.3	12.9	15.4	16.9	17.2	16.9	14.1	11.5	9.1
Summer	10.5	10.2	11.2	13.3	15.9	18.3	19.9	20.2	19.2	17.1	14.5	12.1	12.2

Design ground temperature for 'Heating load' worksheet

7.2

For 'Cooling load' worksheet

20.2

Reduction factor for 'Annual heating' worksheet

0.59



## Areas determination

Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment				
	Treated floor area	1	1050,20	m²	Treated floor area according to PHPP manual				
A	North windows	2	40,55	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	1,282	3618	2915
A	East windows	3	51,84	m²		East windows	1,310	7963	6401
A	South windows	4	47,77	m²		South windows	1,312	8592	5786
A	West windows	5	28,57	m²		West windows	1,315	3059	2798
A	Horizontal windows	6	0,00	m²		Horizontal windows			
A	Exterior door	7	5,76	m²	Please subtract area of door from respective building assembly	Exterior door	2,000		
A	External wall - Ambient	8	790,12	m²	Temperature zone "A" is ambient air	External wall - Ambient	1,242	5271	6257
B	External wall - Ground	9	0,00	m²	Temperature zone "B" is the ground	External wall - Ground			
A	Roof/Ceiling - Ambient	10	688,64	m²		Roof/Ceiling - Ambient	0,986	18101	20752
B	Floor slab / Basement ceiling	11	692,29	m²		Floor slab / Basement ceiling	1,442		
		12	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
		13	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
X		14	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor ( 0 < f < 1):				
					Factor for X				
					75%				
						Thermal bridges - Overview	Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	636,60	m	Units in m	Thermal bridges Ambient	0,061		
P	Perimeter thermal bridges	16	160,98	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,090		
B	Thermal bridges FS/BC	17	0,00	m	Units in m	Thermal bridges FS/BC			
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour			
Total thermal envelope						Average therm. envelope	1,255		

[Go to building components list](#)

Area input																	2-Sorting: BY ID								
Area no.	Building assembly description	To group No.	Assigned to group	Quantity	x (	a [m]	x	b [m]	+	User determined [m²]	-	User subtraction [m²]	-	Subtraction window areas [m²]	) =	Area [m²]	Selection building assembly / Building system	U-Value [W/(m²K)]	Deviation from North	Angle of inclination from the horizontal	Orientation	Reduction factor shading	Exterior absorptivity	Exterior emissivity	
	Projected building footprint	0	Projected building footprint	1	x (		x		+		-		)		=	0,0									
	Treated floor area	1	Treated floor area	1	x (		x		+	1050,20	-		)		=	1050,2									
	Exterior door	7	Exterior door	1	x (		x		+	5,76	-		)	-	=	5,8	Exterior door	2,00							
1	Grīdas grunts/ zāle	11	Floor slab / Basement ceiling	1	x (		x		+	251,80	-		)	0,0	=	251,80	01ud-Grīda uz grunts/ zāle	1,8809	0	180	Hor	0,00	0,00	0,90	
2	Grīdas grunts/ pārējas telpa	11	Floor slab / Basement ceiling	1	x (		x		+	414,51	-		)	0,0	=	414,51	02ud-Grīda uz grunts/ pārējas telpas	1,1474	0	180	Hor	0,00	0,00	0,90	
3	Pagraba pārsegums	11	Floor slab / Basement ceiling	1	x (		x		+	25,98	-		)	0,0	=	25,98	08ud-Pagraba pārsegums	1,8868	0	180	Hor	0,00	0,00	0,90	
4	Jumts	10	Roof/Ceiling - Ambient	1	x (		x		+	692,29	-	3,66	)	0,0	=	688,64	04ud-Jumts	0,9864	0	0	Hor	1,00	1,00	0,90	
5	Z siena	8	External wall - Ambient	1	x (		x		+	223,19	-		)	40,6	=	182,64	03ud-Arsienas	1,2420	19	90	North	0,70	0,70	0,90	
6	D siena	8	External wall - Ambient	1	x (		x		+	223,19	-		)	47,8	=	175,42	03ud-Arsienas	1,2420	199	90	South	0,70	0,70	0,90	
7	R siena	8	External wall - Ambient	1	x (		x		+	257,28	-		)	28,6	=	228,72	03ud-Arsienas	1,2420	289	90	West	0,70	0,70	0,90	
8	A siena	8	External wall - Ambient	1	x (		x		+	257,28	-	2,10	)	51,8	=	203,35	03ud-Arsienas	1,2420	109	90	East	0,70	0,70	0,90	
9					x (		x		+		-		)	0,0	=										
10					x (		x		+		-		)	0,0	=										
11					x (		x		+		-		)	0,0	=										
12					x (		x		+		-		)	0,0	=										
13					x (		x		+		-		)	0,0	=										
14					x (		x		+		-		)	0,0	=										
15					x (		x		+		-		)	0,0	=										
16					x (		x		+		-		)	0,0	=										
17					x (		x		+		-		)	0,0	=										
18					x (		x		+		-		)	0,0	=										
19					x (		x		+		-		)	0,0	=										
20					x (		x		+		-		)	0,0	=										
21					x (		x		+		-		)	0,0	=										
22					x (		x		+		-		)	0,0	=										
23					x (		x		+		-		)	0,0	=										
24					x (		x		+		-		)	0,0	=										
25					x (		x		+		-		)	0,0	=										
26					x (		x		+		-		)	0,0	=										
27					x (		x		+		-		)	0,0	=										
28					x (		x		+		-		)	0,0	=										
29					x (		x		+		-		)	0,0	=										

## Areas determination

Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment				
	Treated floor area	1	1050,20	m²	Treated floor area according to PHPP manual				
A	North windows	2	40,55	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	1,282	3618	2915
A	East windows	3	51,84	m²		East windows	1,310	7963	6401
A	South windows	4	47,77	m²		South windows	1,312	8592	5786
A	West windows	5	28,57	m²		West windows	1,315	3059	2798
A	Horizontal windows	6	0,00	m²		Horizontal windows			
A	Exterior door	7	5,76	m²	Please subtract area of door from respective building assembly	Exterior door	2,000		
A	External wall - Ambient	8	790,12	m²	Temperature zone "A" is ambient air	External wall - Ambient	1,242	5271	6257
B	External wall - Ground	9	0,00	m²	Temperature zone "B" is the ground	External wall - Ground			
A	Roof/Ceiling - Ambient	10	688,64	m²		Roof/Ceiling - Ambient	0,986	18101	20752
B	Floor slab / Basement ceiling	11	692,29	m²		Floor slab / Basement ceiling	1,442		
		12	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
		13	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
X		14	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor ( 0 < f < 1):				
					Factor for X				
					75%				
						Thermal bridges - Overview	Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	636,60	m	Units in m	Thermal bridges Ambient	0,061		
P	Perimeter thermal bridges	16	160,98	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,090		
B	Thermal bridges FS/BC	17	0,00	m	Units in m	Thermal bridges FS/BC			
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour			
Total thermal envelope			2345,53	m²		Average therm. envelope	1,255		

[Go to building components list](#)

30					x (	x	+	-	) -	0,0	=								
31					x (	x	+	-	) -	0,0	=								
32					x (	x	+	-	) -	0,0	=								
33					x (	x	+	-	) -	0,0	=								
34					x (	x	+	-	) -	0,0	=								
35					x (	x	+	-	) -	0,0	=								
36					x (	x	+	-	) -	0,0	=								
37					x (	x	+	-	) -	0,0	=								
38					x (	x	+	-	) -	0,0	=								
39					x (	x	+	-	) -	0,0	=								
40					x (	x	+	-	) -	0,0	=								
41					x (	x	+	-	) -	0,0	=								
42					x (	x	+	-	) -	0,0	=								
43					x (	x	+	-	) -	0,0	=								
44					x (	x	+	-	) -	0,0	=								
45					x (	x	+	-	) -	0,0	=								
46					x (	x	+	-	) -	0,0	=								
47					x (	x	+	-	) -	0,0	=								
48					x (	x	+	-	) -	0,0	=								
49					x (	x	+	-	) -	0,0	=								
50					x (	x	+	-	) -	0,0	=								
Aend																			

## Areas determination

Kultūras nams / Climate: Jelgava / TFA: 1050 m<sup>2</sup> / Heating: 212,3 kWh/(m<sup>2</sup>a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m<sup>2</sup>a)

Summary						Building assembly overview	Average U-value [W/(m <sup>2</sup> K)]	Radiation-gains heating season [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment			
	Treated floor area	1	1050,20	m <sup>2</sup>	Treated floor area according to PHPP manual			
A	North windows	2	40,55	m <sup>2</sup>	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	1,282	3618
A	East windows	3	51,84	m <sup>2</sup>		East windows	1,310	7963
A	South windows	4	47,77	m <sup>2</sup>		South windows	1,312	8592
A	West windows	5	28,57	m <sup>2</sup>		West windows	1,315	3059
A	Horizontal windows	6	0,00	m <sup>2</sup>		Horizontal windows		
A	Exterior door	7	5,76	m <sup>2</sup>	Please subtract area of door from respective building assembly	Exterior door	2,000	
A	External wall - Ambient	8	790,12	m <sup>2</sup>	Temperature zone "A" is ambient air	External wall - Ambient	1,242	5271
B	External wall - Ground	9	0,00	m <sup>2</sup>	Temperature zone "B" is the ground	External wall - Ground		
A	Roof/Ceiling - Ambient	10	688,64	m <sup>2</sup>		Roof/Ceiling - Ambient	0,986	18101
B	Floor slab / Basement ceiling	11	692,29	m <sup>2</sup>		Floor slab / Basement ceiling	1,442	
		12	0,00	m <sup>2</sup>	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
		13	0,00	m <sup>2</sup>	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
X		14	0,00	m <sup>2</sup>	Temperature zone "X": Please provide user-defined reduction factor ( 0 < f <sub>t</sub> < 1):			
					Factor for X			
					75%			
						Thermal bridges - Overview	Ψ [W/(mK)]	
A	Thermal bridges Ambient	15	636,60	m	Units in m	Thermal bridges Ambient	0,061	
P	Perimeter thermal bridges	16	160,98	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,090	
B	Thermal bridges FS/BC	17	0,00	m	Units in m	Thermal bridges FS/BC		
I	Building element towards neigh	18	0,00	m <sup>2</sup>	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope			2345,53	m <sup>2</sup>		Average therm. envelope	1,255	

[Go to building components list](#)

Thermal bridge inputs														Sortierung ändern		
No.	Thermal bridge - denomination	Group No.	Assigned to group	Quan- tity	x (	Length [m]	-	Subtraction length [m]	)=	Length ℓ [m]	User determined psi value [W/(mK)]	User determined f <sub>RAI=0,25</sub> (optional)	or	Selection building system	Ψ-Value [W/(mK)]	f <sub>RAI</sub> -Requirement met?
1	Jumts	15	Thermal bridges Ambient	1	x (	181,52	-		)=	181,52	0,080		or		0,080	
2	Grīda uz grunts/ pārējas telpas	16	Perimeter thermal bridges	1	x (	160,98	-		)=	160,98	0,090		or		0,090	
3	Durvis	15	Thermal bridges Ambient	1	x (	13,24	-		)=	13,24	0,090		or		0,090	
4	Logi	15	Thermal bridges Ambient	1	x (	421,30	-		)=	421,30	0,050		or		0,050	
5	Pagraba pārsegums	15	Thermal bridges Ambient	1	x (	20,54	-		)=	20,54	0,090		or		0,090	
6					x (		-		)=				or			
7					x (		-		)=				or			
8					x (		-		)=				or			
9					x (		-		)=				or			
10					x (		-		)=				or			
11					x (		-		)=				or			
12					x (		-		)=				or			
13					x (		-		)=				or			
14					x (		-		)=				or			
15					x (		-		)=				or			
16					x (		-		)=				or			
17					x (		-		)=				or			
18					x (		-		)=				or			
19					x (		-		)=				or			
20					x (		-		)=				or			
21					x (		-		)=				or			
22					x (		-		)=				or			
23					x (		-		)=				or			
24					x (		-		)=				or			
25					x (		-		)=				or			
26					x (		-		)=				or			
27					x (		-		)=				or			
28					x (		-		)=				or			
29					x (		-		)=				or			
30					x (		-		)=				or			
31					x (		-		)=				or			
32					x (		-		)=				or			

## Areas determination

Kultūras nams / Climate: Jelgava / TFA: 1050 m<sup>2</sup> / Heating: 212,3 kWh/(m<sup>2</sup>a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m<sup>2</sup>a)


Summary						Building assembly overview	Average U-value [W/(m <sup>2</sup> K)]	Radiation-gains heating season [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment			
	Treated floor area	1	1050,20	m <sup>2</sup>	Treated floor area according to PHPP manual			
A	North windows	2	40,55	m <sup>2</sup>	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	1,282	3618
A	East windows	3	51,84	m <sup>2</sup>		East windows	1,310	7963
A	South windows	4	47,77	m <sup>2</sup>		South windows	1,312	8592
A	West windows	5	28,57	m <sup>2</sup>		West windows	1,315	3059
A	Horizontal windows	6	0,00	m <sup>2</sup>		Horizontal windows		
A	Exterior door	7	5,76	m <sup>2</sup>	Please subtract area of door from respective building assembly	Exterior door	2,000	
A	External wall - Ambient	8	790,12	m <sup>2</sup>	Temperature zone "A" is ambient air	External wall - Ambient	1,242	5271
B	External wall - Ground	9	0,00	m <sup>2</sup>	Temperature zone "B" is the ground	External wall - Ground		
A	Roof/Ceiling - Ambient	10	688,64	m <sup>2</sup>		Roof/Ceiling - Ambient	0,986	18101
B	Floor slab / Basement ceiling	11	692,29	m <sup>2</sup>		Floor slab / Basement ceiling	1,442	
		12	0,00	m <sup>2</sup>	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
		13	0,00	m <sup>2</sup>	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
X		14	0,00	m <sup>2</sup>	Temperature zone "X": Please provide user-defined reduction factor ( 0 < f <sub>t</sub> < 1):	Factor for X		
						Thermal bridges - Overview	Ψ [W/(mK)]	
A	Thermal bridges Ambient	15	636,60	m	Units in m	Thermal bridges Ambient	0,061	
P	Perimeter thermal bridges	16	160,98	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,090	
B	Thermal bridges FS/BC	17	0,00	m	Units in m	Thermal bridges FS/BC		
I	Building element towards neigh	18	0,00	m <sup>2</sup>	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope			2345,53	m <sup>2</sup>		Average therm. envelope	1,255	

[Go to building components list](#)

33					X (	-	) =						or			
34					X (	-	) =						or			
35					X (	-	) =						or			
36					X (	-	) =						or			
37					X (	-	) =						or			
38					X (	-	) =						or			
39					X (	-	) =						or			
40					X (	-	) =						or			
41					X (	-	) =						or			
42					X (	-	) =						or			
43					X (	-	) =						or			
44					X (	-	) =						or			
45					X (	-	) =						or			
46					X (	-	) =						or			
47					X (	-	) =						or			
48					X (	-	) =						or			
49					X (	-	) =						or			
50					X (	-	) =						or			
TBend																

Window area orientation	Global radiation (mean orientations)	Shading	Dirt	Non-vertical radiation incidence	Glazing fraction	g-Value	Solar irradiation reduction factor	Window area	Window U-Value	Glazing area	Average global radiation	Transmission losses heating period	Heating gains solar radiation heating period
Standard values →	kWh/(m²a)							m²	W/(m²K)	m²	kWh/(m²a)	kWh/a	kWh/a
North	90	0,82	0,95	0,85	0,74	0,64	0,49	40,55	1,28	29,87	96	4534	1225
East	195	0,78	0,95	0,85	0,63	0,64	0,40	51,84	1,31	32,77	228	5925	3004
South	292	0,84	0,95	0,85	0,63	0,64	0,43	47,77	1,31	29,94	286	5467	3719
West	191	0,70	0,95	0,85	0,61	0,64	0,35	28,57	1,32	17,54	158	3277	1005
Horizontal	322	1,00	0,95	0,85	0,00	0,00	0,00	0,00	0,00	0,00	322	0	0
Total or average value for all windows.						0,64	0,42	168,72	1,30	110,11		19203	8953

Orientation	Transmission losses heating period (kWh/a)	Heating gains solar radiation heating period (kWh/a)
North	4534	1225
East	5925	3004
South	5467	3719
West	3277	1005
Horizontal	0	0



**Recommendation for  $U_{W,installed}$  [W/(m<sup>2</sup>K)]**

[Go to glazing list](#) [Go to window frames list](#)

	0,65	0,70	0,80	0,45
--	------	------	------	------

[illegible]

87,2

[illegible]



## Ventilation data

Energy balance calculation with PHPP Version 9.6a

Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)

Treated floor area $A_{TFA}$	m²	1050	(Areas' worksheet)
Room height h	m	3,55	
Volume of ventilated space ( $A_{TFA} \cdot h$ ) $V_V$	m³	3723	(Worksheet 'Annual heating')

### Ventilation type

Please select

1-Balanced PH ventilation with HR

### Infiltration air change rate

Wind protection coefficients e and f				
Coefficient e for wind protection class		Several side exposed	One side exposed	
No protection		0,10	0,03	
Moderate protection		0,07	0,02	
High protection		0,04	0,01	
Coefficient f		15	20	

Wind protection coefficient, e		For annual demand: 0,07		For heating load: 0,18		
Wind protection coefficient, f		15		15		
Air change rate at press. test	n <sub>50</sub>	1/h	1,89	1,89	Net air volume for press. test V <sub>n50</sub>	Air permeability q <sub>50</sub>
				3723	m <sup>3</sup>	3,00 m <sup>3</sup> /(hm <sup>2</sup> )

Excess extract air		For annual demand: 0,00		For heating load: 0,00	
Infiltration air change rate	n <sub>V,Rest</sub>	1/h	0,132	0,331	

### Selection of ventilation input - Results

PHPP offers two methods for dimensioning air quantities and choosing the ventilation unit. With "Standard data input for balanced ventilation", supply or extract air quantities for residential buildings and parameters for ventilation systems with a maximum of 1 ventilation unit can be planned. Projects with up to 10 different ventilation units and air quantities determined according to rooms or zones can be entered in the 'Addl vent' worksheet. Please select your design method here:

Ventilation unit / Heat recovery efficiency design		Average air flow rate m³/h	Average air change rate 1/h	Extract air excess (extract air system) 1/h	Effective heat recovery efficiency unit [-]	Humidity recovery efficiency [-]	Specific power input Wh/m³	Heat recovery efficiency SHX [-]
<input type="checkbox"/>	Standard design ('Ventilation' worksheet, see below)							
<input checked="" type="checkbox"/>	Multiple ventilation units, non-res ('Addl vent' worksheet)	1181	0,32	0,00	0,0%	0,0%	0,00	0,0%
					Cooling recovery	Efficiency SHX $\eta^*_{SHX}$		
						0%		

### Average interior humidity during winter operation

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
24%	23%	29%	31%	39%	52%	62%	61%	49%	39%	32%	25%



m <sup>2</sup>	<b>1050</b>	(‘Areas’ worksheet)
m	<b>3,55</b>	(Worksheet ‘Annual heating’)
m <sup>3</sup>	<b>3723</b>	(Worksheet ‘Annual heating’)
P	<b>16,0</b>	(‘Ventilation’ worksheet)
°C	<b>18</b>	(Worksheet ‘Annual heating’)
°C	<b>2,3</b>	(‘Ventilation’ worksheet)
°C	<b>8,0</b>	(‘Ground’ worksheet)
d/a	<b>225</b>	(‘Heating’ worksheet)
<b>ventilation with HR</b>		
		(‘Ventilation’ worksheet)

Ventilation unit no.	Description of the unit	Design		Annual average value		
		$V_{SUP}$ m³/h	$V_{ETA}$ m³/h	$V_{SUP}$ m³/h	$V_{ETA}$ m³/h	Air ch.rt. 1/h
1	Visas telpas	3723	3723	1181	1181	---
2						---
3						---
4						---
5						---
6						---
7						---
8						---
9						---
10						---

[illegible]

## Recommendations for dimensioning air quantities

It is strongly recommended to use building materials that cause no or very low VOCs/odours instead of increasing the outdoor air volume in order to clear the air.

This holds true independently from the chosen approach to determine air quality: emissions of all sources in the room should be considered, e.g. furniture, carpets and ventilation or air-conditioning unit.

Also in non-residential buildings, the number of persons is fundamentally important for assessing the volume air flow rates. For good indoor air quality volumes between 20 to 30 m<sup>3</sup>/h/person are sufficient.

Higher outdoor air amounts may lead to excessively dry indoor air in winter. The air flow rates are specified by classification according to EN 13779. The classification must be agreed with the client in advance.

IDA 3 is adequate for office buildings. IDA 4 has proven satisfactory for school buildings as flushing ventilation is carried out during breaks anyway. For typical outdoor air CO<sub>2</sub> concentrations of around 400-500 ppm,

it is possible to comply even with 1500 ppm. Exceeding this figure temporarily is permissible.

- Recommended for residential buildings: around 30 m<sup>3</sup>/(h person)

- Recommended for residential buildings: around 30 m³/(h person)
- Recommended for offices and similar uses: around 30 m³/(h person) (AMEV: 28 m³/(h person); EN 13779 / IDA 3: at least 24 m³/(h person))
- Recommended for schools and day care centres: 15 to 20 m³/(h person) (Source: Guidelines for energy-efficient educational buildings, Passive House Institute, 2010)
- Recommendation for sport halls: 60 m³/(h person) (DIN 18032-1)

In case the ventilation is to be used intermittently (turned off at night), then it should be flushed in the morning, approx. 1 to 2 hours before building is occupied. This should be done in order to refresh air from emissions such as VOCs. Flushing the building causes that the ventilation system works for a longer period (utilisation time + flushing phase). Please consider this at design stage.

Dimensioning of air quantities

When dimensioning the air quantities, please consider the design recommendations given above.  
The operation period of the ventilation can be determined on the basis of daily utilisation hours, including flushing phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be taken into account by means of reduction factors.

Room no.	Amount a	Room name	Allocation to ventilation unit (No.)	Area A m²	Clear height h m	Room vol. A x h m³	Volume flow per room			Air chng. rt. per room n 1/h	Utilisation times		Duration of holidays d	Reduction factor 1	Operation red. 1	Reduction factor 2	Operation red. 2	Reduction factor 3	Operation red. 3	Annual average value:			
							V <sub>SUP</sub> m³/h	V <sub>ETA</sub> m³/h	V <sub>TRANS</sub> m³/h		h/d h	d/week d								V <sub>SUP</sub> m³/h	V <sub>ETA</sub> m³/h	V <sub>TRANS</sub> m³/h	Change rate 1/h
1	1	Visas telpas	1	1050	3,55	3723	3723	3723		1,00	12	6		90%	60%	50%	40%			1181	1181		0,32
2																							
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							
12																							
13																							
14																							
15																							
16																							
17																							
18																							
19																							
20																							
21																							
22																							
23																							
24																							
25																							
26																							
27																							
28																							
29																							
30																							
Additional lines: Please mark complete lines above, copy and paste multiple times																				1181	1181	---	0,32

### Ventilation unit selection

Up to 10 different ventilation units are considered. By changing the amount, identical units can be considered. The data from PHI certified ventilation units as well as the entry data lines for user data for other ventilation units can also be found in the worksheet 'Components'. When choosing to use a compact unit the standard design in the 'Ventilation' worksheet has to be used.

[Go to ventilation units list](#)

Ventilation unit no.	Quantity	Description of ventilation units	Selection of type of ventilation	Design vol. flow per unit m³/h	Application range for volume flow rate from to m³/h	Electrical efficiency Wh/m³	Pressure loss calculation			Application range		Interior location (x)	Exterior location (x)	Heat recovery efficiency		Energy recovery efficiency [-]	Frost protection necessary	Subsoil HX		Frost protection (electr. / hydr.)				
							ODA-SUP ΔP <sub>Duct</sub> Pa	ETA-EHA ΔP <sub>Duct</sub> Pa	Additional ΔP <sub>Intern</sub> Pa	per line ΔP <sub>External</sub> Pa	Subtractor ΔP <sub>Intern</sub> Pa			Unit	Effective [-]			Efficiency of heat recovery	Effectiveness of heat recovery	Type perature	Limit temperature °C	Useful Energy kWh/a		
<a href="#">Change sorting type</a>																								
1	1	Visas telpas	03ud-Dabīgā ventilācija	3723	1862	3723	0,00				-	-	x		0,00	0%	0%	N/A		0%	1-No		0	
2																					1-No		0	
3																					1-No		0	
4																					1-No		0	
5																					1-No		0	
6																					1-No		0	
7																					1-No		0	
8																					1-No		0	
9																					1-No		0	
10																					1-No		0	
																						Total (directly electric)		0
																						Total (hydraulic and heat generator)		0

### Data entries for duct sections between the ventilation unit and the thermal envelope

The duct sections between the ventilation unit and the thermal envelope should be as short as possible and should be well insulated, whether the ventilation unit is located indoors or outdoors. The dimensions of these duct sections can be entered here. The heat losses of the overlying duct sections will be considered for the effective heat recovery efficiency. One section of a duct entered here may also be used for multiple ventilation units.

If in the section "Ventilation unit - selection" (above) a ventilation unit is selected as multiple units (amount larger than 1 for identical units), then the corresponding duct sections may simply be entered (duct sections for one ventilation unit).

Temperature of installation location 0,0 (only enter when at least one unit is installed outside of the thermal envelope)

[illegible]

Additional lines: Please mark complete lines above, copy and paste multiple times

## Energy balance calculation with PHPP Version 9.6a

Kultūras nams / Climate: Jelgava / TFA: 1050 m<sup>2</sup> / Heating: 212,3 kWh/(m<sup>2</sup>a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m<sup>2</sup>a)

Interior temperature:	18 °C	Interior temperature summer:	25 °C
Building type:	Kultūras nams		
Treated floor area $A_{TFA}$ :	1050 m <sup>2</sup>		
Occupancy:	16,0 Pers		
Number of dwelling units:	1		
Annual heating demand $q_{Heating}$ :	222943 kWh/a	Annual useful cooling dem. $q_{Cool}$ :	1365 kWh/a
Length of heating period:	225 d	Length cooling period:	183 d
Average heating load $P_{ave}$ :	41,2 kW	Average cooling load $P_{Average}$ :	0,3 kW
Marginal usability of additional heat gains:	100%	Marginal utility of additional heat losses:	1%

Inside thermal envelope				
1	2	3	4	5

Length of distribution pipes	$L_H$	m
Nominal width of pipe		mm
Insulation thickness		mm
Insulation reflective coating?		-
Thermal conductivity of insulation		W/(mK)
Heat loss coefficient per m of insulated pipe		W/(mK)
Insulation quality of mountings, pipe suspensions, etc.		-
Thermal bridge supplement		W/K
Total heating loss coefficient per m of pipe	$\Psi$	W/(mK)
Temp. of the room through which the pipes pass	$\vartheta_X$	°C
Design forward flow temperature	$\vartheta_V$	°C
Design system heating load	$P_{\text{heating}}$	kW
Forward flow temperature control ('x' if appropriate)		
Design return flow temperature	$\vartheta_R$	°C
Annual heat emission per m of plumbing	$q_{HL}$	kWh/(m·a)
Possible utilisation factor of released heat	$\eta_G$	-
<b>Annual heat losses of heating distribution</b>	$Q_{HL}$	kWh/a
<b>Annual heat losses of heating storage</b>		kWh/a
<b>Annual heat losses of heating</b>		kWh/a
<b>Performance ratio of heat distribution</b>	$ea_{+HL}$	

363,0				
20				
0				
x				
0,039				
0,410				
2 - Moderate	1-None	1-None	1-None	1-None
13,306				
0,447				
18	18	18	18	18
55,0	55,0	55,0	55,0	55,0
85,2	85,2	85,2	85,2	85,2
x	x	x	x	x
44,4				
47				
100%				
0				

### Outside thermal envelope

1	2	3	4	5
---	---	---	---	---

[illegible]

## Total values

Absolute	Specific
----------	----------

kWh/a	kWh/(m²a)
0	0,0
0	0,0
0	0,0
100%	

12,6
7,0
0%
20
8,0
0
6912

DHW demand for showers, per person and day (with 60°C)	litre/person/d
DHW demand others, per person and day (with 60°C)	litre/person/d
Performance of shower drain-water heat recovery	-
Effective DHW demand	$V_{DHW}$ litre/person/d
Average cold water temperature of the supply	$\vartheta_{TW}$ °C
DHW demand for washing machines and dishwashers non-ele	kWh/a
<b>Effective useful heat DHW</b>	$Q_{DHW}$ kWh/a

kWh/a	kWh/(m <sup>2</sup> a)
6912	6,6


Auxiliary calculation - DHW demand calculation (for non-res)

Days of use per year [d/a] 250

DHW demand for showering: 12,6  
DHW demand for other uses: 7,0

Application	Used?	Single-lever mixer?	Time of use per use	Amount of uses according to type of use	Flow rate	Useful temperature	Equivalent average amount of water @ 60°C	Equivalent average amount of water @ 60°C	Useful heat @ 60°C
	-	-	min	-	l/min	°C	l/(WE*d)	l/(P*d)	kWh/a
Shower	x	x	4,0	1,0	8,0	38	295	18	4469
Hand wash basin	x	x	2,0	3,0	4,0	30	162	10	2458
Washing stand		x	1,0	0,4	8,0	38			
Bidet		x	1,0	0,1	8,0	38			
Bathing		x	10,0	0,0	15,0	38			
Tooth brushing		x	0,1	1,0	4,0	30			
Cooking/drinking		x	0,3	1,0	6,0	45			
		N/A							
		N/A							
		N/A							
		N/A							
		N/A							
Dishwashing		x	0,6	1,0	6,0	45			
Cleaning the kitchen		x	0,5	1,0	6,0	38			
Cleaning rooms	x	x	1,0	0,1	6,0	38	0	0	7
		N/A							
		N/A							
		N/A							
		N/A							
		N/A							

DHW demand according to use



Auxiliary calculation - shower drain-water heat recovery

DHW distribution

Temp. of room through which the pipes pass  
Design forward flow temperature

$\vartheta_x$   
 $\vartheta_{dist}$

°C  
°C

Inside thermal envelope				
1	2	3	4	5
18,0	18,0	18,0	18,0	18,0
60,0	60,0	60,0	60,0	60,0

Outside thermal envelope				
1	2	3	4	5
21,0	21,0	21,0	21,0	21,0
60,0	60,0	60,0	60,0	60,0

Total values	
Absolute	Specific

DHW circulation pipes

Length of circulation pipes (forward + return flow)  
Nominal width of pipe  
Insulation thickness  
Insulation reflective coating?  
Thermal conductivity of insulation  
Heat loss coefficient per m of insulated pipe  
Insulation quality of mountings, pipe suspensions, etc.  
Thermal bridge supplement  
Total heating loss coefficient per m of pipe

$L_{HS}$   
  
  
  
  
  
  
 $\Psi$

m  
mm  
mm  
-  
W/(mK)  
W/(mK)  
-  
W/K  
W/(mK)

32,2				
20				
30				
-				
0,040				
0,173				
2 - Moderate	1-None	1-None	1-None	1-None
1,726				
0,227				
18,0				
55				
6570				
59				
1886				

2 - Moderate	1-None	1-None	1-None	1-None

kWh/a	kWh/(m²a)
1886	1,8

DHW individual pipes

Exterior pipe diameter  
Accumulated length per single pipes  
Amount of tapping points in building  
Average pipe length per tapping point  
Tap openings per person per day  
Utilisation days per year  
Heat loss per tap opening  
Amount of tap openings per year and person  
Annual heat loss of individual pipes

$d_{U\_Pipe}$   
 $L_U$   
 $n_{tapping\ point}$   
 $L_{U,\ average}$   
  
  
 $q_{individual}$   
 $n_{tap}$   
 $Q_U$

m  
m  
-  
m  
-  
d  
h/tap opening  
ings per year  
kWh/a

0,020				
42,00				
6,00				
7,0				
5				
250				
0,0848				
1250				
1696				


kWh/a	kWh/(m²a)
1696	1,6

Total heat losses of DHW distribution

Performance ratio of DHW distribution pipes

$Q_{WL}$   
 $ea_{+HL}$

-

kWh/a	kWh/(m²a)
3582	3,4
152%	

## Storage heat losses

		Storage 1	Storage 2	Buffer storage tank (only heating)	Compact unit		
Selection of storage tank		2-DHW only	0-No storage tank	0-No storage tank	0-No		
Storage necessary for HP							
Solar DHW connection							
Heat loss rate	W/K	0,6	0,9				
Storage volume	litre	30	160		---		
Standby fraction	-						
Location of storage tank, inside or outside of thermal envelope		1-Inside	1-Inside	1-Inside			
Temperature of mechanical room	°C	18,0					
Typical storage tank temperature	°C	60,0					
Manual entry of storage temperature	°C						
Average standby heat losses storage tank	W	23					
Additional heat losses storage tank, solar operation	W			---	---		
Possibly utilisation factor of heat losses		---	---		---		
Annual heat losses DHW storage tank	kWh/a	205		---		205	0,2
Annual heat losses buffer storage tank		---	---		---		

Auxiliary calculation - heat losses through storage tank according to EU efficiency classes							
Storage tank volume	Litre	30,0	160,0				
ErP classification	-	A	A	C			
Maximum permissible standby heat loss	W	25	41				
Heat loss ratio for PHPP calculation	W/K	0,6	0,9				

## Total energy demand of domestic hot water

Heat losses of DHW distribution and storage	$Q_{WL}$	3787	3,6
Performance ratio DHW-distribution + storage	$\eta_{a,WL}$	155%	
Total heating demand of DHW system			
Including storage tank	$Q_{g,DHW}$	10699	10,2

Cooling distribution

Length of distribution pipes  
Nominal width of pipe  
Insulation thickness  
Insulation reflective coating?  
Thermal conductivity of insulation  
Heat loss coefficient per m pipe  
  
Temp. of room through which the pipes pass  
Design forward flow temperature  
Dimensioning of cooling load of the system  
Forward flow temperature control ('x' if appropriate)  
Design return flow temperature  
Annual heat absorption per m of pipe  
Possibly utilisation factor of this heat absorption  
**Annual heat losses of cooling distribution**  
  
**Performance ratio cold water distribution pipes**

$L_H$  m  
mm  
mm  
-  
 $\Psi$  W/(mK)  
  
 $\vartheta_x$  °C  
 $\vartheta_v$  °C  
 $P_{cooling}$  kW  
  
 $\vartheta_R$  °C  
 $q^*_{HL}$  kWh/(m·a)  
 $\eta_G$  -  
 $Q_{HL}$  kWh/a  
  
 $ea_{+HL}$  -

Inside thermal envelope				
1	2	3	4	5
25,0	25,0	25,0	25,0	25,0
6,0	6,0	6,0	6,0	6,0

Outside thermal envelope				
1	2	3	4	5
25,0	25,0	25,0	25,0	25,0
6,0	6,0	6,0	6,0	6,0

Total values	
Absolute	Specific

kWh/a	kWh/(m²a)
0	0,0
100%	



Treated floor area $A_{TFA}$ :	1050,2	m <sup>2</sup>
Auxiliary electricity demand:	2344,9	kW
<b>PER factors:</b>		<b>PER</b>
Electricity:	1,35	
RE gas / Natural gas:	1,75	
Energy carrier for DHW:		
Solar fraction of DHW	0%	
Marginal performance ratio DHW:		

	Shading	Dirt factor	Non-perpendicular air radiation	Glazing fraction
North	0,82	0,95	0,85	0,74
East	0,78			0,63
South	0,84			0,63
West	0,70			0,61

		Facade with windows					
Lighting / non-residential	Net ground area	Room category	Power of nominal lighting	Deviation from North	Orientation	Light transmission glazing	Window existing?
Room / Zone	m²		Lux	Degrees		-	[x]

Geometry: input of a typical room				
Room depth	Room width	Room height	Lintel height	Window width
m	m	m	m	m

Daylight utilisation	User data: Installed lighting power	Installed lighting power (standard)	Lighting control	Motion detector used?	Lighting check	Utilisation hours per year	User determined: Lighting full load hours
	W/m <sup>2</sup>	W/m <sup>2</sup>		[x]		h/a	h/a

Full load hours of lighting	Electricity demand (kWh/a)	Spec. electricity demand (kWh/(m <sup>2</sup> a))
h/a	kWh/a	kWh/(m <sup>2</sup> a)

[illegible][illegible][illegible]

Office equipment		Room category	Within the thermal envelope [1/0]	Existing [1/0]		Quantity		Power consumption [W]		Utilisation hours per year [h/a]		Relative absenteeism		Duration of utilisation in energy saving mode [h/a]		Useful energy (kWh/a)		Electricity demand [kWh/a]	
		2								9	20	18							
PC 1		42-Theatre auditorium	1	1	*	4	*	150	*	1001	*(1-	0	)	=		601	=	600,6	
PC in energy saving mode			1			4	*	2,0	*	1001	*	0		=		0	=	0,0	
Monitor 1		42-Theatre auditorium	1	1	*	4	*	150	*	1001	*(1-	0	)	=		601	=	600,6	
Monitor in energy saving mode			1			4	*	2,0	*	1001	*	0		=		0	=	0,0	
PC 2			1	0	*		*	80	*	0	*(1-	0	)	=		0	=	0,0	
PC in energy saving mode			1			0	*	2,0	*	0	*	0		=		0	=	0,0	
Monitor 2			1	0	*		*	28	*	0	*(1-	0	)	=		0	=	0,0	
Monitor in energy saving mode			1			0	*	2,0	*	0	*	0		=		0	=	0,0	
Copier		42-Theatre auditorium	1	1	*	0	*	400	*	1001			-	0	)	=	0	=	0,0
Copier in energy saving mode			1			0	*	30	*	0				=		0	=	0,0	
Printer		42-Theatre auditorium	1	1	*	1	*	250	*	1001			-	0	)	=	250	=	250,3
Printer in energy saving mode			1			1	*	2	*	0				=		0	=	0,0	
Server		22-Group office	1	1	*	0	*	50	*	2750				=		0	=	0,0	
Server in energy saving mode			1			0	*	2,0	*	8760			-	2750	)	=	0	=	0,0
Telephone system					*		*		*	8760				=		0	=	0,0	
					*		*		*					=		0	=	0,0	
					*		*		*					=		0	=	0,0	
					*		*		*					=		0	=	0,0	
					*		*		*					=		0	=	0,0	
					*		*		*					=		0	=	0,0	
					*		*		*					=		0	=	0,0	

Kitchen / Aux. electricity		Room category (predominant utilisation pattern of building)	Within the thermal envelope [1/0]	Existing [1/0]	Days of utilisation per year [d/a]	Number of meals per day of use	Norm consumption	Useful energy [kWh/a]	Non-electric fraction	Electric fraction	Additional demand	Marginal performance ratio	Solar fraction	Non-electric demand (kWh/a)	Electricity demand [kWh/a]		
8																	
kWh / Meal																	
Cooking:			1		*	0	*	0,25	=	0	{	*	0%	100%	=	0,0	
1-Electricity										*		0%	100%	=	0		
kWh / Cover																	
Dishwashing					*	0	*	0,10	=	0	{	*	0%	100%	=	0,0	
2-Cold water connection										*		0%	100%	=	0		
kWh/d																	
Refrigerating					365						{	*	0%	*(1+ 0,30 ) *	1,20	*(1- 0,00 ) = 0	0,0
Citas iekārtas	1	1		250			2,00	=	0	*		100%					500,0
									500	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*	100%					0,0	
									0	*							

Total	13748	kWh	0	0,0	13748	kWh/a
Specific demand			0,0	0,0	13	kWh/(m²a)

# Internal heat gains for non-residential buildings

Energy balance calculation with PHPP Version 9.6a

Kultūras nams / Climate: Jelgava / TFA: 1050 m² / Heating: 212,3 kWh/(m²a) / Freq. overheating: 0 % / PER: 1024,4 kWh/(m²a)

Utilisation: 22-Other

IHG 1,79 W/m²

1,79 W/m²

Type of values used: 4-PHPP calculation ('IHG non-res' worksheet)

Enter here results from cell above: 1,79 W/m²

Persons: 16,0 P		Treated floor area: 1050,2 m²		Heating period: 225 d/a		Room temperature: 18 °C		Internal heat gains aux. electricity: 399 W					
Persons	Selection of user profile	Select	Activity of persons	Planning 0 = according to ground area or usable zone 1 = according to occupancy	Number of occupants	Ground area of useful zone [m²]	Average occupancy [Pers./m²]	Heat emitted per person [W]	Utilisation hours per year [h/a]	Relative presence	Utilisation period [h/a]	Average heat release persons [W]	
Persons A	42-Theatre auditorium	3	>10 yr., standing or light work	1 Planning with occupancy	{ 16 }*	{ 1050,20 }	27 Not a standard value	100	9	18	8760	183	
Persons B			Invalid input		{ }	{ }	Not a standard value	0	0	1,00	8760	0	
Persons C			Invalid input		{ }	{ }	Not a standard value	0	0	1,00	8760	0	
Persons D			Invalid input		{ }	{ }	Not a standard value	0	0	1,00	8760	0	
Persons E			Invalid input		{ }	{ }	Not a standard value	0	0	1,00	8760	0	
Persons F			Invalid input		{ }	{ }	Not a standard value	0	0	1,00	8760	0	
Persons G			Invalid input		{ }	{ }	Not a standard value	0	0	1,00	8760	0	
Evaporation (person specific)			Invalid input		{ 16 }*	{ }	Not a standard value	0	1001	1,00	8760	0	
Lighting / Equipment / Aux. electricity							Useful energy [kWh/a]				Availability	Utilisation period [h/a]	Average heat release
Lighting							9452				1	8,76	1079
Office applications (within therm. envelope)							1451				1	8,76	166
Cooking (within therm. envelope)							0				0,5	8,76	0
Dishwashing (within therm. envelope)							0				0,3	8,76	0
Cooling (within therm. envelope)							0				1	8,76	0
Other (within thermal envelope)							500				1	8,76	57
Auxiliary appliances (see 'Aux Electricity' worksheet)													399
Heat loss due to cold water (calculation from column AJ)	On/Off [1 / 0]	Predominant utilisation pattern of building (Data transferred from 'Electricity non-res' worksheet; input kitchen)	Number of WCs (user data)	Amount of WCs: Utilisation of standard values for schools?	Number of WCs (calculation value)	DT: Cold water temp - Room temp. [K]	Occupied days per year [d/a]	Loss daytime [W]	Loss night-time [W]	Availability	Utilisation period [d/a]	Average power cold water	
Cold water due to flushing WC	0	2			0	-10,0	0	0	-8	1	365	0	
Total IHG												W	1884
Specific IHG												W/m²	1,8
Heat available from internal sources							225 d/a					kWh/(m²a)	10

Pirms												
CO2 emisiju un primārās enerģijas aprēķins												
Enerģijas patēriņa pakalpojums	Energoreses	kWh/m <sup>2</sup> g	MWh/g	Sezonālās efektivitātes koeficients	CO <sub>2</sub> emisijas faktors, kgCO <sub>2</sub> /MWh	CO <sub>2</sub> emisijas kgCO <sub>2</sub>	$f_{Pren}$	$f_{Pren}$	PE nren kWh/m <sup>2</sup> g	PE ren kWh/m <sup>2</sup> g	PE tot kWh/m <sup>2</sup> g	CO <sub>2</sub> emisijas kgCO <sub>2</sub> /m <sup>2</sup>
Apkure	Fosilais kurināmais (Dīzeļdegviela)	212,29	222,943	0,90	279	69112	1,10	0,00	259,46	0,00	259,46	65,81
Karstā ūdens sagatavošana	Fosilais kurināmais (Dīzeļdegviela)	10,19	10,699	0,90	279	3317	1,10	0,00	12,45	0,00	12,45	3,16
Ventilācija	Elektroenerģija no tīkla	0,00	0,000	1,00	109	0	1,90	0,60	0,00	0,00	0,00	0,00
Apgaismojums	Elektroenerģija no tīkla	9,00	9,452	1,00	109	1030	1,90	0,60	17,10	5,40	22,50	0,98
Dzesēšana	Elektroenerģija no tīkla	5,58	5,857	3,00	109	213	1,90	0,60	3,53	1,12	4,65	0,20
Papildu (apkure)	Elektroenerģija no tīkla	1,76	1,853	1,00	109	202	1,90	0,60	3,35	1,06	4,41	0,19
Papildu (karstā ūdens sagatavošana)	Elektroenerģija no tīkla	0,47	0,492	1,00	109	54	1,90	0,60	0,89	0,28	1,17	0,05
<b>KOPĀ:</b>		<b>239,28</b>	<b>251,29</b>			<b>73927</b>			<b>296,79</b>	<b>7,85</b>	<b>304,64</b>	<b>70,39</b>
				CO <sub>2</sub> emisijas kgCO <sub>2</sub> /m <sup>2</sup>		<b>70,39</b>						
				CO <sub>2</sub> emisijas tCO <sub>2</sub>		<b>73,93</b>						

PĒC												
CO2 emisiju un primārās enerģijas aprēķins												
Enerģijas patēriņa pakalpojums	Energonesējs	kWh/m²g	MWh/g	Sezonālās efektivitātes koeficients	CO <sub>2</sub> emisijas faktors, kgCO <sub>2</sub> /MWh	CO <sub>2</sub> emisijas kgCO <sub>2</sub>	$f_{Pnren}$	$f_{Pren}$	PE nren kWh/m²g	PE ren kWh/m²g	PE tot kWh/m²g	CO <sub>2</sub> emisijas kgCO <sub>2</sub> /m²
Apkure	Fosilais kurināmais (Dīzeļdegviela)	96,52	101,362	0,90	279	31422	1,10	0,00	117,96	0,00	117,96	29,92
Karstā ūdens sagatavošana	Fosilais kurināmais (Dīzeļdegviela)	10,19	10,699	0,90	279	3317	1,10	0,00	12,45	0,00	12,45	3,16
Ventilācija	Elektroenerģija no tīkla	0,00	0,000	1,00	109	0	1,90	0,60	0,00	0,00	0,00	0,00
Apgaisojums	Elektroenerģija no tīkla	9,00	9,452	1,00	109	1030	1,90	0,60	17,10	5,40	22,50	0,98
Dzesēšana	Elektroenerģija no tīkla	5,58	5,857	3,00	109	213	1,90	0,60	3,53	1,12	4,65	0,20
Papildu (apkure)	Elektroenerģija no tīkla	1,76	1,853	1,00	109	202	1,90	0,60	3,35	1,06	4,41	0,19
Papildu (karstā ūdens sagatavošana)	Elektroenerģija no tīkla	0,47	0,492	1,00	109	54	1,90	0,60	0,89	0,28	1,17	0,05
<b>KOPĀ:</b>		<b>123,5</b>	<b>129,7</b>			<b>36237</b>			<b>155,29</b>	<b>7,85</b>	<b>163,15</b>	<b>34,51</b>
				CO <sub>2</sub> emisijas kgCO <sub>2</sub> /m²		<b>34,51</b>						
				CO <sub>2</sub> emisijas tCO <sub>2</sub>		<b>36,24</b>						

Dzesēšanas enerģijas novērtējums							
Nosaukums	Qdz, kW	EER	Qel,kW	h/gadā	Noslodze	Eletribas paēriņš gadā, kWh gadā	Dzesēšanai nepieciešamā enerģija kWh gadā.
PN1	22,70	3	7,57	516	0,5	1952,20	5856,60

5,58 kWh/m2  
gadā