

Nr. p.k.		Materi la nosaukums			Izstr d juma marka		M rvie- n ba		Daudzums		Piez mes				
Z/spr. kabe u guld šana															
1		Sp ku sadalne SS-2					kompl.		1		skat. lapu ELT-4				
		Sadalnes k rba v.a. IP54. Svirs l dzis Inom=50A; ~380V. Grupu autom tiskie sl dži: grupu autom t. sl dzis Inom=10A; ~220V; grupu autom t. sl dzis Inom=16A; ~220V; grupu autom t. sl dzis Inom=16A; ~380V; grupu autom t. sl dzis Inom=40A; ~380V; Nopl dstr vas aizsardz bas relejs 1f Inom=25A, I=30mA; ~220V. Nopl dstr vas aizsardz bas relejs 3f Inom=25A, I=30mA; ~380V. Nopl dstr vas aizsardz bas relejs 3f Inom=40A, I=30mA; ~380V. Kopnes, DIN standart .			C- tips  B- tips  B- tips  B- tips		gab. gab.  gab. gab. gab. gab. gab. gab. gab. kompl.		1 1  1 2 2 1 3 2 1 1						
2		Kabelis			NYY-J-5x6		m		20						
3		Kabelis			NYY-J-5x2,5		m		20						
4		Kabelis			NYY-J-3x2,5		m		10						
5		Kabelis			NYY-J-3x1,5		m		10						
6		PVC caurule Ø32					m		20						
7		PVC caurule Ø25					m		20						
8		PVC caurule Ø20					m		20						
9		Citi materi li					kompl.		1						
					Pielikums lapai ELT-3, ELT-4										
izm.	lapa	dokum. Nr.	paraksts	dat.	denssaimniec bas att st ba Platon DENS ATT R ŠANAS STACIJAS PIESL ĢŠANA				Stadija		Ras.		M rogs		
									TP		ELT				
Proj. vad.		D. Žuravikins							Lapa - 1		Lapas - 1				
						Iek rtu un materi lu saraksts.				SIA "LL Premium Designs" Re .nr. 40003347364					